

NSF International

RECOGNIZES

Ak-Kim Kimya San. Ve Tic. A.S.
Turkey

AS COMPLYING WITH NSF/ANSI 60 AND ALL APPLICABLE REQUIREMENTS.
PRODUCTS APPEARING IN THE NSF OFFICIAL LISTING ARE
AUTHORIZED TO BEAR THE NSF MARK.



Certification Program
Accredited by the
Standards Council
of Canada

This certificate is the property of NSF International and must be returned upon request. For the most current and complete information, please access NSF's website (www.nsf.org).

A handwritten signature in black ink, appearing to read "David Purkiss".

March 12, 2014
Certificate# C0176164 - 01

David Purkiss
General Manager, Water Systems



The Public Health and Safety Organization

NSF Product and Service Listings

These NSF Official Listings are current as of **Wednesday, May 14, 2014** at 12:15 a.m. Eastern Time. Please [contact NSF International](#) to confirm the status of any Listing, report errors, or make suggestions.

Alert: NSF is concerned about fraudulent downloading and manipulation of website text. Always confirm this information by clicking on the below link for the most accurate information:

<http://info.nsf.org/Certified/PwsChemicals/Listings.asp?Company=C0176164&Standard=060&>

NSF/ANSI 60 Drinking Water Treatment Chemicals - Health Effects

Ak-Kim Kimya San. Ve Tic. A.S.

Tasköprü Mevkii

39 Yalova

Turkey

90 226 815 3300

Visit this company's website (<http://www.akkim.com.tr>)

Facility : Yalova, Turkey

Aminotrimethylene Phosphonic Acid

Trade Designation

AKUA SAN 7391

Product Function

Reverse Osmosis Antiscalant

Max Use

15mg/L

Miscellaneous Treatment Chemical

Trade Designation

Ammonium Peroxydisulfate

Ammonium Persulfate

Diammonium peroxidisulphate

Peroxydisulfuric Acid Diammonium Salt

Product Function

Oxidant

Oxidant

Oxidant

Oxidant

Max Use

43mg/L

43mg/L

43mg/L

43mg/L

Polyaluminum Chlorosulfate[AL]

Trade Designation

Aqualenc F1

Polyaluminium Chlorosulfates (PACS)

Product Function

Coagulation & Flocculation

Coagulation & Flocculation

Max Use

50mg/L

50mg/L

[AL] Based on an evaluation of health effects data, the level of aluminum in the finished drinking water shall not exceed 2 mg/L.

Number of matching Manufacturers is 1

Number of matching Products is 7

Processing time was 0 seconds